

TEST REPORT

Issued to: **Divine Happy Senior Secondary School**
A-2 Block Paschim Vihar, New Delhi-110063

Date: **21.09.2022**
Report No.: **QRAL/20220919/W-069**

SAMPLE DETAILS

Name of the Sample	: Drinking Water	Date of Sample Receipt	: 19.09.2022
Sample Description	: Clear Water	Batch No.	: NA
Group	: Water	Manufacturing Date	: NA
Sample Quantity	: 500 ml	Expiry/ Best Before	: NA
Sample Packaging Details	: Plastic bottle	Test method Deviation	: NA
Discipline	: Microbiological Testing	Period of Testing	: 19.09.2022 to 21.09.2022
Sampling Method	: QRAL/MICRO/GEN/SOP-D-01		

TEST RESULTS

Sr. No.	Parameters	Units	Results	Specifications	Test Method
1.	Standard Plate Count	cfu/ml	<1	<1	IS 1622: 1981
2.	Coliform	MPN/100ml	<2 (Absent)	Absent	IS 1622: 1981
3.	E.coli	MPN/100ml	<2 (Absent)	Absent	IS 1622: 1981

Remarks: Sample passing all above test parameter as per water specifications.

~End of Report~

Prepared By
(Ms. Unnati)

Checked By
(Ms. Prerna)

Authorized Signatory
(Mrs. Kumari Preeti Gupta)

Note:

- ❖ The results apply to the samples as received.
- ❖ The results listed refer only to the tested sample and applicable parameter.
- ❖ This report, in full or in part, shall neither be used for advertising or as an evidence in any court of law nor reproduced, expect when in full, without the written permission of the Director.
- ❖ Sample will be destroyed after three weeks from the date of issue of the test report (In case of non-perishable products only)

TEST REPORT

Issued to: Divine Happy Senior Secondary School
A-2 Block Paschim Vihar, New Delhi-110063

Date: 21.09.2022
Report No.: QRAL/20220919/W-069

SAMPLE DETAILS

Name of the Sample	: Drinking Water	Date of Sample Receipt	: 19.09.2022
Sample Description	: Clear Water	Batch/ Request Number	: NA
Group	: Water	Manufacturing Date	: NA
Sample Quantity	: 500 ml	Expiry/ Best Before	: NA
Sample Packaging Details	: Plastic bottle	Test method Deviation	: NA
Discipline	: Chemical	Period of Testing	: 19.09.2022 to 21.09.2022
Sampling Method	: Sampling Done by Customer		

TEST RESULTS

Sr. No.	Parameters	Units	Results	Specifications (as per IS-3328:1993)	Test Method
1.	pH	-	6.60	6.5-8.5	IS 3025 (P-11)
2.	Colour	Hazen	<1	Max 5.0	IS 3025 (P-4)
3.	Odour	NA	Agreeable	Agreeable	IS 3025 (P-5)
4.	Taste	NA	Agreeable	Agreeable	IS 3025 (P-8)
5.	TDS	mg/l	121	500	IS 3025 (P-16)
6.	Conductivity	µS/cm	168	-	IS 3025(P-14)
7.	Turbidity	NTU	<1	1	IS 3025 (P-10)
8.	TSS	mg/l	ND	-	IS 3025 (P-17)
9.	Chloride	mg/l	22.80	250	IS 3025 (P-32)
10.	Total hardness	mg/l	43.12	200	IS 3025 (P-21)
11.	Total alkalinity	mg/l	31.64	200	IS 3025 (P-23)

Remarks: Sample passing all above test parameter as per water specifications.

~End of Report~

Prepared By
(Ms. Unnati)

Checked By
(Mr. Brijesh Kumar)

Authorized Signatory
(Dr. Gaurav Maheshwari)

Note:

- ❖ The results apply to the samples as received.
- ❖ The results listed refer only to the tested sample and applicable parameter.
- ❖ This report, in full or in part, shall neither be used for advertising or as an evidence in any court of law nor reproduced, except when in full, without the written permission of the Director.
- ❖ Sample will be destroyed after three weeks from the date of issue of the test report (In case of non-perishable products only)